

Town of Cedar Lake
Public Works
Cedar Lake Water Department
8550 Lake Shore Drive, Cedar Lake, IN 46303
PWSID# 5245067
Consumer Confidence Drinking Water Report
1-1-2021 to 12-31-2021

This is a report on the quality of the drinking water supplied by the Cedar Lake Water Utility for the fiscal year 2021. Questions regarding this report should be to the Cedar Lake Water Department at (219)-374-7478, Water Superintendent, Ryan Kuiper.

According to these assessments, your water system has a low risk of being susceptible to contamination. Further information about the source water assessment can be obtained by contacting Mr. Kevin Spindler of IDEM's Drinking Water Branch at (317)-234-3243.

Cedar Lake Water Utility routinely monitors for contaminants in the drinking water according to Environmental Protection Agency and Indiana Department of Environmental Management requirements. These contaminants include:

- **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum productions, and can also result from gas stations, urban storm runoff and septic systems.
- **Radioactive Contaminants**, which can be naturally occurring or the result of oil and gas production and mining activities.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does NOT necessarily indicate that the water poses and health risks. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at (800) 426-4791.

Where does my water come from? Between 60-72% of Indiana's population relies on ground water for drinking and household use. The Cedar Lake Water Utilities source is the Silurian Devonian Aquifer. The Cedar Lake Water Utility has two (2) wells.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2021	1	1 - 1	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2021	5	4.7 - 6.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2021	14	12.2 - 15.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2021	0.01	0.01 - 0.01	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2021	0.54	0.54 - 0.54	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	08/02/2018	4.3	4.3 - 4.3	0	15	pCi/L	N	Erosion of natural deposits.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. Environmental Protection Agency and Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level (MCL): Highest allowable amount of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): Level of a contaminant in drinking water below which no known or expected risk to health exists. MCLG's allow for a margin of safety.

Parts per Million (ppm): One part per million corresponds to one minute in two years.